




No. F6/DFS/MS/School/NDZ/2025/ 1001

Dated: 18/08/2025

**FIRE SAFETY CERTIFICATE**

Certified that the Nav Jeevan Adarsh Public School located at A - Block, Street No. 16, Part - 3, Circular Road, Sonia Vihar, Delhi - 110094, earlier building comprised of Ground plus two upper floors for which NOC/FSC was issued by this department vide letter no. F6/DFS/MS/School/2022/NDZ/296 dated 21/03/2022, owned/occupied by Nav Jeevan Adarsh Public School is now comprised of Ground plus three upper floors have complied with fire prevention and fire safety requirements in accordance with rule 33 of DFS Rules of this department on 23/07/2025 in presence of Mr. Amit Bansal (Principal) and that the building premises is fit for occupancy class (Group - B) "Educational Building" for Ground plus three upper floors only with effect from 18/08/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 18/08/2025 at New Delhi by.

  
(VIRENDRA SINGH)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

**Copy to: -**

1. The Dy. Director of Education, B - Block, Yahuma Vihar, Delhi - 110053.
2. The Principal, Nav Jeevan Adarsh Public School at A - Block, Street No. 16, Part - 3, Circular Road, Sonia Vihar, Delhi - 110094.

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained firefighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner / occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.